

CONSTANT RATE PUMPING TEST - RECOVERY DATA SHEET

CONSENT No				¹ Description of datum point from which measurements were made (eg ground level, dip tube)		
Pumping Test at		Eastgate 2b				
NGR						
Observations From ¹		borehole plunger				
Position ²				² height above ground level (m)		
Date	Time	Elapsed Time		Depth of water level below datum (m)	Drawdown (m)	Comments
		Minutes	Hours			
9/6/14	10.57	0		0		
		1		0.20		
		2		0.34		
		3		0.46		
		4		0.58		
		5		0.70		
		6		0.81		
		7		0.925		
		8				
		9		1.135		
		10		1.22		
		11		1.32		
		12		1.42		
		13		1.52		
		14		1.60		
		15		1.70		
		16		1.79		
		17		1.88		
		18		1.96		
		19		2.04		
		20		2.20		
		*22		2.35		
		24		2.50		
		26		2.63		
		28		2.77		
		30		2.89		
		32		3.01		
		34		3.12		
		36		3.23		
		38		3.34		
		*40		3.42		
		45		3.65		
		50		3.83		
		55		4.00		
	11.52	60	1	4.14		
		65		4.255		
		70		4.35		
		75		4.44		
		80		4.50		
		85		4.55		
	12.28	90		4.59		drizzle
		*100		4.62		
		110		4.65		
		120	2	4.67		

CONSTANT RATE PUMPING TEST - RECOVERY DATA SHEET

CONSENT No	¹ Description of datum point from which
------------	--

Pumping Test at				measurements were made (eg ground level, dip tube)		
NGR						
Observations From ¹						
Position ²				² height above ground level (m)		
Date	Time	Elapsed Time		Depth of water level below datum (m)	Drawdown (m)	Comments
		Minutes	Hours			
		130		4.68		
		140		4.68		heavy rain
		150		4.68		
		160	2	4.68		
	13.48	170		4.67		
	13.58	180	3	4.67		
		*200		4.65		
		210		4.65		
		240	4	4.63		
		289				
	15.58	300	5	4.60		stopped raining 10
	16.15	349		4.58		mins
	17.15	380	5	4.56		last measurement ag
		409				
		420	7			
		469				
		480	8			
		*540	9			
		600	10			
		660	11			
		720	12			
		780	13			
		840	14			
		900	15			
		960	16			
		1020	17			
		1080	18			
		1140	19			
		1200	20			
		1260	21			
		1320	22			
		1380	23			
		1440	24			